

## CLARIFICATIONS

**Contract title:** Public works contract for the Supply, delivery, installation, testing of solar systems and user training at Anaka General Hospital Neonatal Unit, Nwoya District.

**Reference:** UGA180371T-10106

Please note that the contracting authority will not further respond to any other question as provided for under point 3.3 “Information”. As a reminder, tenders must be received **before 30<sup>th</sup> June, 2023 at 2:00 pm** Kampala time. Late bids will not be accepted.

N°	Issue / question raised	Response
1.	<p>You stated that you need 40pcs of 486Watts modules which translates to 19,440Watts.</p> <p>Does this mean that we strictly quote for the 486W modules or our focus should be to provide the total wattage required?</p>	<p>As much as possible 486Watts modules would be desirable considering potential space limitations. However, the overriding requirement is the total power (wattage required).</p> <p>In summary, yes other equivalent module configuration would be acceptable.</p>