

CLARIFICATIONS

Contract title: Public contract for the supply, delivery and installation of generators, user training and repair of generator shelters at Rwesande HCIV in Kasese, Buwenge General Hospital in Jinja, and Mpumudde HCIV in Jinja.

Reference: UGA22009-10051

As a reminder, tenders must be received **by 13th January 2025 at 11:00 AM, Kampala time**. It must be sent to email: uga_csc_tenders@enabel.be. Late bids will not be accepted.

N°	Issue / question raised	Response
1.	Are there installation materials on sites like change over switches and cables since the bid is for supply and installation of generators but installations materials have not been talked about anywhere in the bid?	Check the attached BoQ as annex: “UGA22009-10051_Unpriced-BOQ-for-Supply-of-Generators-for-Health-facilities” . Bill 3: Installation and accessory works, items 1-9.
2.	Is site survey allowed to determine the materials required for the installation of the generators?	Yes, it is allowed. Where necessary, the prospective bidder could request for an introduction letter from Enabel to allow them into the facilities
3.	Will the generator specs of 30KVA Prime Power be acceptable?	30kVA/24kW prime power and 33kVA/26.4kW standby
4.	Is the 8-hour running fuel capacity of the generator of about 85 Liters sufficient for your operations or you require a larger fuel tank for extended running time?	An 8-hour running capacity at full load for a 60kVA typically requires a 100-120L tank. Please maintain the range specified in the Annex: “UGA22009-10051_Electro-Mechanical-Specifications-for-Supply-of-Generators-for-Health-facilities”
5.	Do integrated control panels configuration meet your expectations?	Yes, an integrated control panel is okay