Addendum n°1 to the Tender TZA22002-10395 "Supply of BSF Equipment in Pemba"

With reference to the tender published on 08 October 2026, the Contracting Authority hereby amends the tender as follows:

1. PUBLISHING THE QUESTIONS AND ANSWERS (Q&A) DOCUMENT

Through Addendum No. 1, the Contracting Authority formally publishes the Questions and Answers (Q&A Document).

All other provisions of the Tender Specifications remain unchanged. This addendum forms an integral part of the Tender Specifications and must be taken into account when preparing and submitting a tender.


** End of Addendum No 1**

S/No	TZA22002-10395-Supply of BSF Equipment in Pemba - Questions and Answers	
	QUESTIONS	**ANSWERS**
1.	VAT and customs duties: Under the DDP delivery requirement, how should bidders account for any applicable VAT exemptions and import-duty procedures?	This project is exempt from VAT. Chapter 4, Section H, Clauses 23.5 and 23.6 of the tender specifications set out the procedures for obtaining VAT exemption. Enabel will facilitate the process of securing the applicable VAT exemption; however, tenderers remain responsible for complying with all relevant requirements and procedures related to importation and customs clearance.
2.	Installation requirements: Will the beneficiary facilities provide the necessary electrical connections, installation space and site access for equipment installation and commissioning?	**Electrical connections:** Internal wiring has been completed at both Mkoani and Chake-Chake facilities. However, electricity connections are still pending and are expected to be available before equipment commissioning. **Installation space:** Designated installation areas have been identified and prepared at both facilities. **Site access and delivery:** Both facilities are still under completion. Equipment, delivery and installation will be coordinated with site readiness. Temporary storage may be arranged if necessary.
3.	Technical information: Are there any additional site-specific installation requirements or equipment interface drawings available to prospective bidders?	Yes. The site drawings for the Mkoani and Chake Chake sites are available and are provided as Annex 1 to this Q&A document.
4.	Can you confirm that a UK-registered company may submit a tender directly, subject to meeting the published eligibility and qualification requirements?	Yes. A UK-registered company may submit a tender directly, provided that it complies with all the eligibility, exclusion, and qualification requirements set out in the tender document. The tender specifications do not restrict participation based on the country of registration of the tenderers.

********END OF QUESTIONS AND ANSWERS********

ANNEX 1

□WTC



SASA
Green and Smart Cities programme

Service for peace LVIA

EUROPEAN UNION


PROJECT:Kijani Pemba-Strengthening urbanecological resilience in Chake and Mkoani

SUB-PROJECT: construction of waste processing facility(□WTC) in Mkoani-LAY□UT

DESIGNED/DRAWN BY:Lay Volunteers International Association(LVIA)

DIMMENSIONS:In meters(m),Unless otherwise stated

SCALE:	DATE:
1:100	April,2026



SASA Green and Smart Cities programme Service for peace LVIA EUROPEAN UNION	PROJECT:Kijani Pemba-Strengthening urbanecological resilience in Chake and Mkoani	SUB-PROJECT: construction of waste processing facility in Chake and Mkoani-LAYOUT	DESIGNED/DRAWN BY:Lay Volunteers International Association(LVIA)	DIMMENSIONS:In meters(m),Unless otherwise stated	SCALE: 1:100 DATE: April,2026